

MUNICIPAL WATER SUPPLY SERVICE AREA DEMAND AND PUMPAGE IN THE OZAUKEE COUNTY PLANNING AREA: 2000 AND 2035

Utility	2000 – Actual			2035 – Estimated		
	Average Water Use Demand ^a (gallons per day in thousands)	Average Daily Pumpage ^a (gallons per day in thousands)	Maximum Daily Pumpage ^a (gallons per day in thousands)	Average Water Use Demand (gallons per day in thousands)	Average Daily Pumpage (gallons per day in thousands)	Maximum Daily Pumpage (gallons per day in thousands)
City of Cedarburg Light and Water Commission	1,256	1,418	2,150	1,694	1,913	2,937
We Energies-Water Services ^b	464	672	1,727	3,140	4,547	6,352
City of Port Washington Water Utility	1,151	1,334	1,702	1,681	1,947	3,127
Village of Belgium Water Utility	221	267	605	325	393	1,107
Village of Fredonia Municipal Water Utility	144	171	398	326	388	825
Village of Grafton Water and Wastewater Commission	1,130	1,420	2,043	1,884	2,366	3,833
Village of Saukville Municipal Water Utility	1,207	1,261	1,737	1,513	1,580	2,071
Village of Newburg Area ^c	--	--	--	189	223	345
Town of Fredonia-Waubeka Area	--	--	--	65	76	104
Total	5,573	6,542	10,362	10,818	13,435	20,701

^aData based on year 2000 Public Service Commission Reports.

^bProvides service to portions of the City of Mequon and Village of Thiensville.

^cIncludes the entire Village of Newburg service area.

Source: SEWRPC Regional Water Supply Plan.